



BASE OF EXCAVATION TO BE LEVEL AND FREE OF BROKEN ROCK

IF REQUIRED PREPARE A BASE OF 12mm SCREENINGS OR DOLOMITE

TANK SHOULD BE HALF FILLED WITH WATER FOLLOWING INSTALLATION TO MAXIMISE STABILITY AND STOP FLOATATION

WEIGHT APPROX. 6.0 TONNE

— — EXCAVATION REQUIREMENT
3m x 3m

NB. DEPTH OF EXCAVATION DETERMINED BY DRAIN DEPTH

BIOCYCLE BIO7000