



BASE OF EXCAVATION TO BE LEVEL AND FREE OF BROKEN ROCK

IF REQUIRED PREPARE A BASE OF 12mm SCREENINGS OR DOLOMITE

TREATMENT TANK MAY NOT BE INSTALLED WITHIN 3.0m OF ANY BOUNDARY OR BUILDING

TANK SHOULD BE HALF FILLED WITH WATER FOLLOWING INSTALLATION TO MAXIMISE STABILITY AND STOP FLOATATION

WEIGHT APPROX. 6.5 TONNE

— — EXCAVATION REQUIREMENT

3m x 3m

NB. DEPTH OF EXCAVATION DETERMINED BY DRAIN DEPTH

BIOCYCLE MODEL 5800