



— — EXCAVATION REQUIREMENT  
3m x 3m  
NB. DEPTH OF EXCAVATION  
DETERMINED BY DRAIN DEPTH

BASE OF EXCAVATION TO BE LEVEL AND FREE  
OF BROKEN ROCK

IF REQUIRED PREPARE A BASE OF 12mm SCREENINGS  
OR DOLOMITE

TREATMENT TANK MAY NOT BE INSTALLED WITHIN  
3.0m OF ANY BOUNDARY OR BUILDING

TANK SHOULD BE HALF FILLED WITH WATER  
FOLLOWING INSTALLATION TO MAXIMISE STABILITY  
AND STOP FLOATATION

WEIGHT APPROX. 6.5 TONNE

**BIOCYCLE MODEL 6800**