



EXCAVATION REQUIREMENT
3m x 3m

NB. DEPTH OF EXCAVATION
DETERMINED BY DRAIN DEPTH

BASE OF EXCAVATION TO BE LEVEL AND FREE
OF BROKEN ROCK

IF REQUIRED PREPARE A BASE OF 12mm SCREENINGS
OR DOLOMITE

TREATMENT TANK MAY NOT BE INSTALLED WITHIN
3.0m OF ANY BOUNDARY OR BUILDING

TANK SHOULD BE HALF FILLED WITH WATER
FOLLOWING INSTALLATION TO MAXIMISE STABILITY
AND STOP FLOATATION

WEIGHT APPROX. 6.5 TONNE

BIOCYCLE MODEL 8200